

## Open Tender Clarification no. 3

European Banking Authority Tender: Supply of Office Furniture EBA/2013/001/OPS/SUP/OP

Date: 22 February 2013

No.	Questions	EBA Response
1	<p>In the technical specification you have specified the Boardroom Tables 1-5 to be 750mm in depth. The proposed tables we supply come in 800mm in depth. I have measured on the plan and it will give you plenty of room.</p> <p>Can we still tender with 800mm table depth of Boardroom Tables 1-5?</p>	<p>No, as it would mean that the tables on the long sides in the boardroom would move outwards by 50mm which raises concerns about the escape routes in case of fire.</p>